



**ROMÂNIA**  
**CONSILIUL JUDEȚEAN MEHEDINȚI**  
str. Traian nr. 89, Drobeta Turnu Severin, cod 220134  
Tel. / Fax: +40 372 521 107;  
E-mail: [cjmehedinti@cjmehedinti.ro](mailto:cjmehedinti@cjmehedinti.ro)

### **Contracting authority' s clarification**

Publication reference: RORS-29, Mehedinți County/ TD-4  
**Works – Rehabilitation/modernization works of county road DJ 607B Bunoaica – Ciresu**

<b>Question</b>		<b>Answer</b>
1.	Please provide us the recipes of the following estimate items	Each bidder will achieve its own consumption rules (recipes) without changing the quantities on the lists.
2.	According to the lists of quantities, concrete type C30 / 37 is used in the L foundation. According to the execution detail the concrete used is C35 / 45. Please clarify.	The concrete class for the L foundation is C 30/37.